

Certificate of compliance

Applicant: SMA Solar Technology AG

Sonnenallee 1 34266 Niestetal **Germany**

Product: Photovoltaic (PV) inverter

Model: SB1.5-1VL-40

SB2.0-1VL-40 SB2.5-1VL-40

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with EN50549-1:2019 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied rules and standards:

EN 50549-1:2019

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

DIN V VDE V 0126-1-1:2006 (4.1 Functional safety)

Automatic disconnection device between a generator and the public low-voltage grid

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: 14TH0397-EN50549-1_2 Certification Program: NSOP-0032-DEU-ZE-V01

Certificate number: U19-0610 Date of issue: 2019-11-20





Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH



Annex to the EN 50549-1 certificate of compliance No. U19-0610

Appendix

Extract from test report according to EN 50549-1

Nr. 14TH0397-EN50549-1_2

Type Approval and declaration of compliance with the requirements of EN 50549-1.							
Manufacturer / applicant:	SMA Solar Technology AG						
	Sonnenallee 1						
	34266 Niestetal						
	Germany						
Micro-generator Type	Photovoltaic (PV) inverter						
Rated values	SB1.5-1VL-40	SB2.0-1VL-40	SB2.5-1VL-40				
MPP DC voltage range [V]	160 – 500	210 – 500	260 – 500				
Input DC voltage range [V]	100 – 600	100 – 600	100 – 600				
Input DC current [A]	10	10	10				
Output AC voltage [V]	230 @ 50Hz / 60Hz (N,PE)	230 @ 50Hz / 60Hz (N,PE)	230 @ 50Hz / 60Hz (N,PE)				
Output AC current [A]	7	9	11				
Output power [VA]	1500	2000	2500				
Firmware version	V03.10.00.R						
Measurement period:	2019-08-02 to 2019-08-23						

Description of the structure of the power generation unit:

The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on two series-connected relays in line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.



Annex to the EN 50549-1 certificate of compliance No. U19-0610

Appendix

Extract from test report according to EN 50549-1

Nr. 14TH0397-EN50549-1_2

Setting of the interface protection: Parameter	Min. disconnection time	Max. disconnection time	Min. operate value	Max. operate value	Standard set value	
Over voltage (stage 1) ^a	0,1s	100s	1,0Vn	1,2V _n	0,2s/1,2V _n	
Over voltage (stage 2)	0,1s	5s	1,0Vn	1,3V _n	0,1s/1,25V _n	
Under voltage (stage 1)	0,1s	100s	0,2V _n	1,0Vn	10s/0,2V _n	
Under voltage (stage 2)	0,1s	5s	0,2V _n	1,0V _n	3s/0,8V _n	
Over frequency	0,1s	100s	1,0f _n	1,04f _n	0,1s/1,03f _n	
Over frequency (stage 1)	0,1s	5s	1,0f _n	1,04f _n	0,1s/1,03f _n	
Under frequency	0,1s	100s	0,94f _n	1,04f _n	0,1s/0,95f _n	
Under frequency (stage 2)	0,1s	5s	0,94f _n	1,04f _n	0,1s/0,95f _n	
Reconnection settings for voltage	Adjus	0,85V _n (195,5V) ≤ V ≤ 1,10V _n (253V)				
Reconnection settings for frequency	Adjusten	49,5Hz ≤ f ≤ 50,2Hz				
Reconnection time		≥ 60s				
Active power gradient after reconnection		10%PEmax / per minute				
Permanent DC-injection		1				
Loss of mains according EN 62116 (LoM)	2s					

Note:

The settings of the interface protection are password protected adjustable in the stated range above.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements of the EN 50549-1:2019.

^a Over voltage – stage1: 10 min-mean-value corresponding to EN 50160.